



Mortar Droppings Collection Device
at Floor Line or
Approx. 10' to 12' Intervals

Owens Corning® FOAMULAR®
CW25 XPS

Hook & Ladder Joint Reinforcement at
16" O.C. w/ Pintle Wire Tie

Air Space (1" Min. - 2" Max.)
Face Brick

Topping Slab

Pre-Cast Hollow Core Plank
*Project Engineering is Required
for Reinforced Bond Beam and
Hollow Core Plank Connections

CMU

NFPA 285 Compliant
Air & Water Barrier

Enclosure Solutions

Concrete Masonry Unit Wall System

Hollow Core Plank at Bearing Wall

Date: 05-03-16	Dwg. no. ES-CM-12	Vertical Section
----------------	-------------------	------------------

NOTE: This drawing is a general reference intended to show common wall system assembly details. Actual details for each product will vary, therefore, details for each project must be reviewed and approved by the Architect of Record. Manufacturers assume no responsibility for final project drawings or field installation.